

## SECTION 092900 - GYPSUM BOARD

### PART 1 - GENERAL

#### 1.1 SUMMARY

A. Section Includes:

1. Interior gypsum board.

#### 1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.

### PART 2 - PRODUCTS

#### 2.1 INTERIOR GYPSUM BOARD

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. American Gypsum.
2. CertainTeed Corp.
3. Georgia-Pacific Gypsum LLC.
4. Lafarge North America Inc.
5. National Gypsum Company.
6. PABCO Gypsum.
7. Temple-Inland.
8. USG Corporation.

- B. Abuse-Resistant Gypsum Board (or match existing): ASTM C 1629/C 1629M.

1. Core: 5/8 inch (15.9 mm), Type X.
2. Long Edges: Tapered.
3. Mold Resistance: ASTM D 3273, score of 10.

- C. Thermal Insulation: As specified in Division 07 Section "Thermal Insulation."

### PART 3 - EXECUTION

#### 3.1 APPLYING AND FINISHING PANELS

- A. Comply with ASTM C 840.

Benton Arena Siding Project 2009

- B. Examine panels before installation. Reject panels that are wet, moisture damaged, and mold damaged.
- C. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments, except floors. Provide 1/4- to 1/2-inch- (6.4- to 12.7-mm-) wide spaces at these locations and finish to match existing.
- D. Gypsum Board Finish Level: Finish panels to match existing.
- E. Remove and replace panels that are wet, moisture damaged, and mold damaged.

END OF SECTION 092900